Certs4Sale
Pass With 100% Guarantee

ISEB Data Centre Management EUCOC

Intermediate Certificate in EU Code of Conduct for Data centres

Thank You for Downloading EUCOC Updated Exam Questions

https://certs4sale.com/bcs/eucoc-pdf-exam-dumps

Question: 1

Why has the EU Code of Conduct on Data Centres been developed?
a. Because data centres are using an increasing amount of power and they need to maximise their efficiency to reduce their impact on the power infrastructure.
b. Because the power consumption of data centres across Europe as a whole needs to fall to meet agreed C02 targets.
c. Because many data centres have outdated designs which focus on perceived reliability at the expense of cost and energy efficiency.
d. Because the energy consumption of data centres has become a significant business cost.
e. Because the United States (US) has taken a significant lead in energy conservation and EU-based data centres need a code of conduct to compete in a global marketplace.

A. a, b, c and d
B. a, c and d
C. b and e
D. e only

Answer: B

Question: 2

Which of the following BEST define the aims of the EU Code of Conduct on Data Centres?
a. To determine and accelerate the application of energy efficient technologies.
b. Develop practical voluntary commitments which when implemented improve the energy efficiency of data centres and in so doing minimise the Total Cost of Ownership (TCO).
c. To develop and promote a set of easily understood metrics to measure the current efficiencies and subsequent improvement.
d. To encourage the closure of data centres that are less energy efficient.
e. To ensure that the EU is visibly taking a lead in this important area of energy conservation.

A. a, b, c and d
B. d and e
C. a, b and c
D. e only

Answer: C

Question: 3

A facility's 'IT load', as defined by the Code of Conduct, includes the power drawn by which of the following?
a. The Power Distribution Units feeding the racks
b. Servers
c. Firewalls
d. Switches
e. Tape libraries

A. b, c. d and e
B. a, d and e
C. b and c
D. b. c and d

Answer: A

Question: 4

'Facility load', as defined by the Code of Conduct, includes the power drawn by which of the following?
a. The UPS.
b. Lighting.
c. Air-conditioning units.
d. Monitors housed in racks.
e. Tape libraries

A. a, b, and c
B. a and d
C. b and c
D. d, and e

Answer: A

Question: 5

The numerical value associated with each Best Practice is shown for the following reason:

A. To allow operators to add up their total score in order that they can be compared with their competitors.
B. To allow the Code of Conduct administrators to properly assess each application.
C. To provide an independent scorecard for data centre owners.

D. To indicate the level of benefit from carrying out a Best Practice.

Answer: D

Question: 6

Which of the following actions should you carry out immediately in your facility, according to the Code of Conduct?

Scenario 1

Your company has just acquired a data centre for its own use that was built in the 1980s. It has been through a number of owners, equipment has been added on an ad-hoc basis and hot-spots abound. You have been tasked with bringing the facility up to the standards required by the Code of Conduct but have very little budget for immediate equipment or software upgrade, and have been given the role of evangelising Green IT.

a. Remove underfloor cabling and place this in overhead trays.
b. Install draught excluders in the bottom of all racks.
c. Install blanking plates between each piece of equipment in each rack.
d. Make sure all your racks are configured on a Hot Aisle\Cold Aisle basis.
e. Replace any solid rack doors with perforated doors.

A. c and d
B. c only
C. a. b. c. and e
D. a. c and d

Answer: B

THANK YOU FOR DOWNLOADING EUCOC UPDATED EXAM QUESTIONS

Note: Thanks For Trying The Demo Of Our EUCOC Exam Product

Visit Our Site to Purchase the Full Set of Actual EUCOC Exam Questions With Answers.

Money Back Guarantee

Click The Link Below

https://certs4sale.com/bcs/eucoc-pdf-exam-dumps